


Safety Codes Act Flow Chart Effective April 1, 2006


Start Equipment Is it a water Does the ls it a Boiler or heater or Not pressure No No equipment No Thermal Liquid equipment under hot-water contain Heating storage the Act. expansible System? exceeding 65° C? fluid? Yes Yes Yes ls it Yes Yes Is it exempt Exempt Not subject to the in the from the Act PEEO? Act? No No PESR does not apply Next page

Act - Safety Codes Act

PESR - Pressure Equipment Safety Regulation

PEEO - Pressure Equipment Exemption Order





Owner's Duties:

An owner of pressure equipment must ensure that the pressure equipment is designed, constructed, installed, operated, maintained and decommissioned in a manner to prevent unintentional release of stored energy, to prevent injury to people and to prevent damage to equipment. These responsibilities include, but are not limited to, the following sections of the Pressure Equipment Safety Regulation:

- 11(3) obtain an owner-user certificate of authorization permit if required by the Administrator.
- 31 certify the pressure piping data report and retain it on file for at least 5 years.
- report unsafe condition, accident or fire.
- ensure that: the pressure equipment meets the requirements of the Regulation and is maintained in good working order; an integrity management system is in place; safe operating limits and operating procedures are established; and operators are competent.
- 38/39 ensure that the pressure equipment is protected against overpressure, and ensure that the overpressure protection system is designed and maintained as required.